

**NOTE**

**Sub:** Additional works to facilitate raising of TATA Power's EHV Overhead lines for Metro Line-4 Project.....resolving of ROW for tower no. T-54 at Lavander Bough HT crossing.

**Ref.:** i) Administrative approval by Hon'ble MC on dated 25.04.2025

ii) TLJ/C.18005819009(KTM)/271 dated 24.03.2025

iii) TLJ/C.18005819009(KTM)/297 dated 05.04.2025

\*\*\*\*

1. **Introduction:** MMRDA is implementing various elevated Metro corridors out of which proposed Metro line -4 from Wadala to Kasarwadavali is approved by Government of Maharashtra. It is observed that various EHV lines are infringing to Proposed Metro line-4 corridors at various locations. The existing EHV lines belonging to M/s TATA Power are infringing with Metro Line alignment at Four locations that are Amar Mahal, Sahakar Cinema, Bhajan Samaj, Lavander bough. There was total 10 HT crossings of M/s TATA Power in the alignment of Metro Line-4 which needed to modify to have adequate clearance. The modification of these EHV lines (10 HT crossings) was allotted to M/s The TATA Power Company Ltd.
2. **Current Status:** The details of HT crossing allotted to M/s TATA Power is as below;

| Sr. No. | HT crossing Location | No. of crossings | Current Status   |
|---------|----------------------|------------------|--|
| 1       | Amar Mahal           | 1                | Height raising work Completed  |
| 2       | Sahakar Cinema       | 2                | Height raising work Completed but the required clearance will be obtained only after completion of new tower (T-54). |
| 3       | Bhajan Samaj         | 2                |  |
| 4       | Lavander Bough       | 2                |  |
| 5       | Shangrilla           | 3                | 02 Nos of transmission line height raising work Completed and 01 nos work is in progress.                            |

As per ref. (ii), While finalising the HT crossing scheme for Sahakar Cinema, Bhajan Samaj & Lavander Bough crossings, M/s TATA power has considered Metro depot at Ghatkopar and 3 x 3 RoW arrangement was proposed up to Tata Powers Vikhroli RSS. As the Ghatkopar depot has been dropped, M/s TATA power has to normalize the lines immediately after Lavander bough crossing. In view of this, M/s TATA Power has submitted the proposal for one new dead end type tower on Trombay - Salsette RoW at location No. 54 to normalize this arrangement from 3 x 3 (modified arrangement to get metro clearance) to 4 x 2 (original arrangement). The new tower at Lavander Bough crossing is required to get

electrical clearances between proposed Metro-4 rail track and bottom most conductor of EHV Overhead lines at Sahakar Cinema, Bhajan Samaj & Lavender Bough crossings.

3. **RoW for proposed Tower (T-54):** Vide reference (i) above, Hon'ble MC sir has accorded the administrative approval for this work. Vide letter at ref(iii), M/s The TATA Power Company Limited has requested that the working space of 10 X 10 Meters will be required for construction of new tower and requested MMRDA to take up with concerned MMRDA Land Department for R&R of proposed tower space for completing proposed tower construction and normalization of third circuit on 220KV Trombay Salsette RoW in 3 x 3 scheme. The proposed location is encroached by hutments & shops. The drawings showing area required for tower base and working space submitted by M/s TATA Power is attached at C.S. 12 and google map for the location is attached at C.S. 13.

4. Hence, it is requested to take up the necessary rehabilitation and resolve the ROW issue to provide location for further completion of the project to M/s Tata Power.

1310  
22/05/2025

05.05.2025  
(Jyotiram Sawant)  
Junior Engineer

C.E./Elect. [Signature]  
05/05/2025

Director (System) [Signature]  
6/5/2025

Add. Collector (SDC) [Signature]  
M. Coll (D.C.)  
Ay. Coll. with the approval of Am. Engineer

सांघिक विकास कक्ष  
3818  
06 May 2025

Metro-4 → Shri. Vikas Patil (DC)

यांच्या व युती कार्यवाही साठी मंडळ

स्वागत (मजदारी वगैरे)

15M  
20.5.24

3  
245

06052025  
298

अदालत प्रकरण सामाजिक विकास कक्षाशी सौमिकीत प्रसन्नाने  
प्राथमिक कार्यवाहीकरिता सदरची नफे सौमिकीत करवण्यात येत आहे

पूर्वसुब्कारील टिपणचि सुवलोकन स्वे.

पूर्व सुब्कारील टिपणचि सुवलोकन केले झयता सदरचो विषय पायाभुत सर्वेक्षणावकाशाचो मखण सामाजिक पिकाय कळाराशी समंधीत झयताने सदरची नकी पुढील कार्याधिकारीता सामाजिक पिकाय कळारुडे अग्रेषित करव्यात या. धाटे.

*Rathod*  
सुभाषक.  
*Sawar*  
स. सुभाषक.

सहा. स. नि. झ. *Sargalwar*

तहसिलदार. *Anvale*  
5/06/2025

उपजिल्हाधिकारी. *Ashima*  
06/06/25

अपर जिल्हाधिकारी. *Ringsar*  
13.06.25

प्रमुख सामाजिक पिकाय कडा. *Jao*  
17/6

स. विकास कडा.  
आवक क्र. 5029  
दिनांक 16 JUL 2025

METRO LAND / MMIRDA  
INWARD / OUTWARD  
NO 10-202  
DATE 26/06/2024

DT-011(R.A)

Dc (Deepak chavan)

*BP*  
31/7/25

*Ru*  
2.4.24

Archany Mule Madam